

## APPENDIX 1

### EQUIPMENT COST ESTIMATES

The following section provides very rough cost estimates for a wide variety of process equipment. It must be remembered in using these charts that there is no such thing as an exact, definite, fixed price for any piece of equipment of a given size or capacity. As with buying merchandise, clothing or a car there are many styles, quality differences, optional features and designs to meet specific needs or services. Presumably charts could be made for each of these variations, but the number would be large and confusing, and for many preliminary estimates the engineer would not know exactly what he wanted at that stage of the design, so only average, representative equipment should be more useful. Again, a range of prices could be shown, but usually a single line is more practical, keeping in mind that the price could quite normally vary considerably depending upon the exact design requirements and the company policy on quality, maintenance, and so on.

With these generalities in mind, the following charts have been taken from a number of sources. Most are from cost estimating articles or books, although some are from recent vendor quotations. In case only a single source was available, that reference has been noted. However, often many sources were available and a somewhat biased consensus of opinion curve was selected. In this case the sources were not noted except for inclusion in the reference list at the end of the appendix. In case different variables were used as the sizing parameter, the most logical one in the author's opinion was selected.

All costs were factored to an early 1987 basis, or a chemical engineering index number of 320. When equations were available for the cost relationship they were listed beneath the charts, and when straight line functions existed for the costs on log-log paper a sizing exponent was given:

$$\text{cost size 2} = \text{cost size 1} \left( \frac{\text{size 2}}{\text{size 1}} \right)^{\text{size exponent}}$$

In a number of references various authors have estimated the fraction of the purchased equipment cost that it takes to install the equipment. This generally included freight and shipping costs, foundations, mounting, and simple electric and piping connections, such as switch gear, starters, flange connections, and so on. Unfortunately these numbers often varied widely, so the range and average are both listed when available:


installed cost = purchase price × installation factor

A similar number that also includes all of the adjacent minor equipment and connections is sometimes listed in the literature (principally by Guthrie 1975 and Ulrich 1984) covering the cost of purchase and installation of the major equipment as well as all of the supporting equipment around each major unit. This is called the module factor, and when available is also listed under the charts as the range given by different authors and the average value.


cost of the installed module = purchase price × module factor

As a final item under the equipment cost graphs, often a simple factor can be used to estimate the cost of some other material, pressure, size, or other variable for the equipment, than is shown on the graph. For instance, the cost of a stainless steel agitated tank is 1.7 times the cost of a mild steel tank (which is shown on the chart). These factors have also been listed when available, and again, sometimes as a consensus of different authors' estimates.

Adsorbers, Activated Carbon  
Mild steel construction, including instruments and controls




Agitators  
Dual turbine blades: mild steel; 30-45 rpm, motor, gear reduction, shaft  
Propeller, mild steel, single blade



Size exponent:	Installation factor:	Factors for:	Range	Average
Turbine:	Range	Turbine:		
>30 HP 0.68	1.20-40	Single blade	0.75-0.85	0.82
4-30 HP 0.56		56-100 rpm	0.57-0.70	0.66
<4 HP 0.23	1.12-32	126-230 rpm	0.37-0.51	0.47
Propeller: 3-100 HP 0.51	Module factor 2.0	316 stainless	1.23-1.87	1.47
1-3 HP 0.42		Propeller:		
		Stainless steel		1.19
		With seal (for closed tank)		1.32

Agitated Tanks\*  
Jacketed, agitated, mild steel



Size exponent 0.53  
Module factor 2.5

Installation factor:


Open tank 1.41 - 66  
Low pressure 1.30 - 57  
Autoclave 1.50 - 70

Material factors:

Stainless steel 1.2 - 2.2, avg. = 1.7  
Glass lined 1.2 - 2.0, avg. = 1.6  
\*See Reactors

## EQUIPMENT COST ESTIMATES 259


Air Conditioning  
Compressor, motor, controls, condenser, refrigerant




Size exponent 0.73  
Installation, Module factor 1.38-53 avg. 1.46

\*One ton = 12,000 Btu

Blenders  
Mild steel construction



Blowers  
30-in. water (~1 psi) to 30 psi; cast iron, with motor



Size exponent:


- 30 psi 0.52
- 10 psi 0.79
- <3 psi variable

Module factor:

- Rotary 2.2
- Centrifugal 2.5



## Boilers



## Size exponents:

Package boilers	0.65
5 - 1,000 HP	0.77
6 - 600 · 10 <sup>3</sup> lb/hr	0.82
Field erected	

\*One HP = 33,500 Btu

## Installation factor:

1.21 - 82 avg.	1.53
----------------	------

## Module factor:

Package	1.8
Field erected	1.8 - 2.0 avg. 1.9


## Pressure factor:

Large package	1.31
400 psi	1.74
500 psi	1.35
Field erected	1.58
1000 psi	
3000 psi	

## Coal fired

Large package	1.61
Field erected	1.36

## Boilers, Waste Heat



## Size exponent 0.75

## Installation factor:


1.40 - 82 avg.	1.67
----------------	------

## Module factor 1.81

## Factors:

High-temperature operation	1.2
Finned tubes	1.5
Alloy-clad tubes	3.0
Mechanical ash removal	1.8
Radiation section	2.0

Buildings  
Office type with air conditioning, restrooms, plaster or equivalent walls, insulation, modest architectural features




Size exponent 0.8

Factors:

- Warehouse 0.25
- Laboratory 1.5
- Manufacturing bldg. 0.5

Centrifuges  
Solid-bowl, screen-bowl, pusher types,  
316 stainless steel




Installation factor:  
Range 1.20-2.02 avg. 1.54

Module factor: 2.0

- Material factors:
- Carbon steel 0.68
  - Monel 1.35
  - Nickel 1.7
  - Hastalloy C 2.6

Chimneys, Stacks  
Carbon steel, lined, insulated, with foundations (tall); No lining (short)




Size exponent, Tall 1.63  
Installation factor: 1.20-28 avg. 1.24

Factors for:  
Brick lined 2.3  
Concrete 3.8  
Diameter  $\frac{D}{55}$  (short) (64 in.)

Material factor, Short  
Acid resistant, Fiberglass 1.3


Classifier, Rake or Spiral  
Mild steel construction



Size exponent 1.32  
Installation factor 1.63-2.61 avg. 2.12

Module factor 2.3

Column Trays  
Mild steel



Material factor:

Brass	1.2
304 stainless	1.5
316 stainless	1.9
347 stainless	2.1
Inconel	3.3
Monel	7.7

Tray type factor:


Turbo grid (stamped)	0.8
Grid, plate, sieve	1.0
Trough, valve	1.2

Number factor:

25	1
20	1.05
15	1.25
10	1.50
5	2.30
1	3.0

Installation factor 1.20

Columns, Distillation, Absorption Towers, etc.  
Mild steel construction, 0-50 psi, vertical



Weight, lb

Material factors

Carbon steel	1.0
Stainless 304	1.7
Stainless 316	2.1
Monel 400	3.6
Titanium	7.7
Carpanter 20 CB-3	3.2
Nickel 200	5.4
Inconel 600	3.6
Incoloy 825	3.7

Other factors

Horizontal vessel 0.6

Pressure  $P^{0.44}$  or see chart


Size exponent  
 $10^5-10^6$  lb 0.78

Installation cost:  
1.29-2.03 avg. 1.72

Module factor  
Vertical 4.16  
Horizontal 3.05




Column Packing



Material Factors, size exponents

Material	Size exponent	Ratio for other material	Material	Size exponent	Ratio for other material
Berl saddles	-1.16	1.24	Interlox saddles	-0.4	0.94
Porcelain	-0.64	0.30	Porcelain	-0.95	0.94
Pall ring SS	-0.95		Polypropylene	-0.5	6.11
Polypropylene			Raschig rings		2.35
			Porcelain		1.58
					0.78
					Stoneware
					Carbon
					Mild steel
					Stoneware


Compressors, Medium-Low Pressure



Size exponents:	Installation factor:	Factors:
Straight lobe	1.30-87; avg. 1.49	Straight lobe:
Sliding vane		Pressure $\left(\frac{P}{20}\right)^{0.16}$
Helical screw	Module factor:	
Reciprocating (air)	2.2-3.1; avg. 2.6	



Compressors, High-Capacity and/or Pressure  
1,000 psi; electric motor drive, gear reducer, steel



Size exponent 0.80

Equation:

$$HP = 0.0044 P_1 Q_1 \ln P_2/P_1$$

$P_1$  = inlet pressure, psi  
 $P_2$  = outlet pressure, psi  
 $Q_1$  = inlet flow rate, cfm


Installation factor:  
1.30-87; avg. 1.49

Module factor:  
2.15-3.1; avg. 2.6

Factors:

Turbine drive	1.13
Gas engine	1.41
Pressure $\left(\frac{P}{1000}\right)^{0.18}$	
Stainless steel	2.5
Nickel alloy	5.0

Conveyors  
Mild steel construction



Size exponent:

Screw conveyor	0.78
Belt conveyor	0.76
Bucket elevator, roll	0.5
Pneumatic conveyor	0.37
Vibrating	1.0

Installation factor:

Range 1.40-2.15 avg. 1.72


Module factors:

Screw, pneumatic, roll	2.2
Belt, bucket, vibrating	2.4

Size factors:

Screw conveyor $\left(\frac{\text{diameter}}{9 \text{ in.}}\right)^{1.2}$	
Belt conveyor $\left(\frac{\text{width}}{16 \text{ in.}}\right)^{0.6}$	
Bucket elevator $\left(\frac{\text{bucket wd. X ht.}}{6 \text{ X } 4 = 24 \text{ in.}^2}\right)^{0.37}$	
Pneumatic conveyor $\left(\frac{\text{diameter}}{3 \text{ in.}}\right)^{0.55}$	
Roll $\left(\frac{\text{width}}{20 \text{ in.}}\right)^{0.55}$ ; 4 in. spacing X 0.84	
Vibrating $\left(\frac{\text{width}}{36 \text{ in.}}\right)^{0.57}$	

Coolers, Quenchers  
Mild steel construction; Cascade cooler, 2 in. diameter pipe




Installation factor:  
1.40-1.85; avg. 1.62

Module Factor:  
Spray chamber, quencher 2.7


Equations:  
Spray chamber:  $\$(358 \times M \text{ scf} + 65,000)$   
Quencher:  $\$(335 \times M \text{ scf} + 12,200)$

Factors:  
Cascade cooler  
 $\left(\frac{\text{pipe diameter}}{2 \text{ in.}}\right)^{0.5}$

Cooling Tower  
15° F range, 10° F approach, 82° F wet bulb



# Crystallizers Mild steel construction




Size exponent:	Installation factor:	Material factors:
Cooling, evaporative	1.30-2.03, avg. 1.80	Stainless steel 2.1
Growth, forced		Copper alloy 1.3
circulation, DTB		Nickel alloy 2.6
Vapor recompression	Module factor: 2.4-2.9, avg. 2.6	Titanium 6.0

\*Courtesy of Swenson.

# Dryers Mild steel construction

## Dryers Mild steel construction




Size exponents:	Installation factor:	Factors:
Rotary dryer	0.45	Rotary to:
Fluid bed	0.48	Roto-Louvre 1.25
Spray dryer	0.29	Vacuum shelf 0.35
		(shelf area)
		Materials:
		Nickel alloy 3.7
		Brick-lined, stainless steel 2.2



## EQUIPMENT COST ESTIMATES 279

Ducts  
Wall thickness 1/8 in.



Size exponent: 1.08  
Installation factor: 1.45


Equations: \$/ft

Mild steel  
Stainless  
Water cooled

Factors:

Mild steel:  
(wall thickness/1/8 in.)<sup>0.68</sup>  
Stainless:  
(wall thickness/1/8 in.)<sup>1.0</sup>

Dust Collectors  
Mild steel construction



Installation factor:  
1.76-2.00; avg. 1.90


Module factors:

Electrostatic precipitators 2.3  
Bag filters 2.2  
Venturi scrubber 2.5  
Cyclone, multicone 3.0

Material factors for

venturi, cyclone scrubbers:  
High temperature with  
membrane, brick lining 1.6  
304 Stainless 1.8  
316L Stainless 2.1  
316L Stainless, clad 1.9  
Monel 3.0  
Monel clad 2.7  
Titanium 3.2


Evaporators\*  
Single effect; stainless steel



Size exponents:		Material factors:	
Forced circulation	0.7	Mild steel	0.44
Falling film, long, short tube	0.53	Copper alloy	0.57
		Nickel alloy	1.22
		Titanium	2.93
Installation factor:		Module factor:	
1.5-2.50; avg. 2.09		Forced circulation	2.9
		Falling Film	2.3

\*Also, see Crystallizers


Fans  
Mild steel; motor, starter; 3/4 in. H<sub>2</sub>O ΔP



Installation factor:		Factors:	
Range: 1.30-2.05; avg. 1.61		Pressure: $\left(\frac{\Delta P}{3.5}\right)^{0.3}$	
Module factor: 2.2		Fiberglass:	1.8
		Stainless steel:	2.5



# Filters Stainless steel



Size exponents:  
 Rotary vacuum drum, leaf 0.39  
 Vacuum table, tilting pan, belt 0.5  
 Pressure leaf, plate & frame 0.61

## Installation factor:

1.19 - 2.21; avg. 1.69


## Module factor:

Rotary table, belt, tilting pan  
 1.4 - 2.8; avg. 2.4  
 Others 2.8

## Factors:

Rotary drum; belt/screw or  
 string discharge 1.22  
 General/paper pulp 2.17-3.38  
 Mild steel/stainless steel 0.69  
 Vacuum table mild steel/SS 0.48  
 Vacuum filter auxiliaries (vac. pump,  
 receivers, etc.), Often ~50% of filter cost

# Flares Mild steel, High Btu\*, with accessories



## Size exponents:

Elevated 0.59  
 Ground 0.39


## Installation factor 1.45

\*High = 1,000; low = 60 Btu/ft<sup>3</sup>

## Factors:

Ground: Low/High\* Btu, 0.3  
 Elevated: Low/High\* Btu, 0.8  
 Corrosive 2.0  
 Guyed (100 ft.), self-supporting  
 (x elevated) 1.3-1.8

### Furnaces Mild steel tubes




**Size exponents:**  
Herschhoff 0.48  
Box 0.70  
Cylindrical 0.78

**Installation factor:**  
1.30-71; avg. 1.52  
Module factor: 2.1

**Material factors:**  
Cylindrical, vertical tubes:  
Stainless steel 1.74  
Chrome/moly 1.44  
with Dowtherm 1.33  
Herschhoff diameter:  
6-19 ft  $(D/6)^{0.55}$   
>19  $(D/6)^{0.65}$

### Generator, Electric Power




**Size exponents:**  
Diesel drive 0.71  
Turbine drive 0.76

**Installation factor:**  
2.22-2.39  
avg. 2.31  
Module factor 2.5

**Factors:**  
Gas/diesel engine 1.81  
Coal/oil, gas (turbine) 1.29

Heat Exchangers; Shell and Tube, Double Pipe, Air Cooled  
Mild steel construction; Shell and tube floating head  
150 psig pressure, 3/4 X 1 in. square pitch, 16 ft tubes



## Size exponent

Shell & tube, Double pipe 0.68  
Air cooled 0.39

## Installation factor

1.23-2.10, avg. 1.61

## Module factor

Shell & tube 3.2  
Double pipe 1.8  
Air cooled 2.2


## Other factors: Exchanger type

Shell & tube to: Kettle reboiler 2.35  
U-tube 1.65  
Fixed tube sheet 1.79

## Shell &amp; tube material factor

$a + (a/100)^b$		$a$	$b$
Shell	SS	1.75	0.13
Tube	SS	2.70	0.07
	CS	2.1	0.13
	monel	3.3	0.08
	CS	5.2	0.16
	Ti	9.6	0.05
	CS moly	1.40	0.05
	moly	1.67	0.16
	CS	Admiralty	1.08

Heat Exchangers: Spiral, Plate and Frame  
304 stainless steel, no insulation



## Size exponent:

Plate & frame 0.78

## Equations:


Spiral plate:  $\$ = 660A^{0.59}$   
Plate & frame:  $\$ = 100A^{0.78}$

## Installation Factor:


Plate & frame: Mild steel 1.70  
Stainless 1.53

## Material Factor:

Mild steel 0.43  
316 stainless 1.1  
Nickel 1.2  
Titanium 2.6




Insulation  
2 in. thickness for pipe






Ion Exchange\*  
Mild steel construction; 465 ppm removed



Size exponent: 0.97  
Module factor 2.0  
Installation factor: 1.58-65, avg. 1.62  
Factor  
Ions removed  $\left(\frac{\Delta}{465}\right)^{0.51}$   
(-35 ppm typical for boiler makeup)  
(-320 ppm typical for cooling tower makeup)

\*See water treating.


Mills: Hammer, Jaw, Gyratory, Roll Crushers



Module factor:  
Hammer 2.8  
Others 2.1  
Installation factor:  
1.30-2.15, avg. 1.83



Mills: Ball, Rod, Pebble (Wet), Jet, Rubbish  
Reduction ratio 34 (i.e., ~ 1/2 in. - 65 mesh; 3/4 in. - 45 mesh)




Size exponent  
Shredder 0.53  
Mills: installed 0.62  
purchased 0.70

Installation factor:  
1.30 - 2.15; avg. 1.83

Modular factor:  
1.8 - 2.8; avg. 2.3

Factors:  
Ball, etc. mills  
Size reduction  
 $\left( \frac{\text{Reduction}}{34} \right)^{1.3}$   
Dry/wet = 1.25

Motors, Drives  
Electric: totally enclosed, fan cooled (TEFC)



Size exponent:  
Electric motors, small 0.86  
Gas turbine, engine 0.76  
Steam turbine 0.41

Module factor:  
Electric 2.0 (1.5 on fans, pumps, compressors)  
Gasoline 2.0  
Gas, steam turbines 3.5


Variable speed drives:  
Ratio  
1.5 to 5/1  
6/1

Factor  
1.0  
1.08

Factors: Electric motors  
Speed, 1800 rpm 1.0  
3600 rpm 1.04  
1200 rpm 1.6  
900 rpm 2.6

Construction: TEFC 1.0  
Explosion proof 1.2  
Drip proof 0.74

Pipe, Pipelines  
Mild steel




Size exponent:  
Pipelines 0.99

Factors:  
304 stainless, schedule 10S  
Bare pipe 2.05  
Traced, insulated 3.4  
Fittings 18  
Valves 94

# EQUIPMENT COST ESTIMATES 295

Presses: Roll, Screw  
Mild steel construction




Installation factor: 2.05

Module factor: 2.4

Material factors:  
Stainless steel 1.5  
Nickel alloy 1.9

Pumps, Centrifugal  
Cast iron, horizontal, includes motor, coupling, base



Factors:

Size exponent	Conventional	In-line	Axial	Mixed
Installation	1.30	1.27	0.79	0.79
Module factor	1.5	1.75	1.58	1.32
Cast steel	1.4	1.3	2.05	1.70
316 stainless	2.0	1.6		
Copper alloy	1.3			
Nickel alloy	3.6			
Titanium	5.7			

Pressure factor:


psi	to 150	150-500	500-1000
In-line	1.00	1.48	1.92
Conventional	1.0	1.52	2.12

Factors:

Conventional: APS/AVS = 1.6  
In-line: vertical/horizontal = 0.89  
Mixed, axial flow: vertical/horizontal = 1.12

## EQUIPMENT COST ESTIMATES 297

Pumps, Miscellaneous  
Mild steel construction



Factors

Size exponent	Reciprocating	Turbine	Chemical Injection
Installation	0.59	0.47	0.52
Module factor	3.3	1.38	1.58
Cast iron	1.0	1.80	2.83
Cast steel	1.8		1.0
Stainless	2.4		1.25
Nickel alloy	5.0		1.95
0-150 psi	1.0		1.0
150-500	1.32		1.37
500-1000	1.53		1.79

General installation factor:

1.25 - 2.40; avg. 1.74


Other size exponents:

Diaphragm	.43
Rotary	.52
Gear	.75
Sump	.15

Factors:


Reciprocating:  $\Delta P (1,000 - 5,000) / (0 - 1,000) = 3.8$   
Sump:  $3600 / 1800 \text{ rpm} = 1.2$   
Chemical injection: Fixed/variable speed = 1.67

Pressure Vessels\*  
Mild steel construction



\*See columns for pressure and material correction factors.

Reactors\*  
304 stainless steel; jacketed; no agitation



Module factors:  
Stainless 1.8  
Glass lined 2.1  
Mild steel 2.3


Installation factor:  
1.40 - 2.10; avg. 1.70

Material factors:  
316 stainless 1.2  
Glass lined .8  
Lead lined .7  
Mild steel .6

\*See agitated tanks.



Refrigeration  
40°F temperature



Size exponent 0.69


Installation, Module factor

\*One ton = 12,000 Btu

Evaporative temperature factors:

+20F	1.5
0	1.9
-20	2.4
-40	3.5

Screens, Vibrating  
Mild steel, single deck



Size exponent: 0.75

Installation factor:

1.45-2.27; avg. 1.85


Module factor: 2.8

Factors:

Double deck	1.6
Stainless steel	1.25
Nickel alloy	1.8




Size Enlargement  
Mild steel construction



Size exponent	Factors		
	Pug mill extruder	Disk, drum granulator	Others
Pug mill	0.15	2.2	2.05
Pellet mill	0.12	1.2	1.2
Pelletizing rolls	0.58	1.4	1.4
Installation factor:	2.05	5.6	0.68

Tanks  
Mild steel construction unless otherwise noted



Size exponent	Factors	
	Module factor	Pressure factor
Small cone top	0.51	1.6
Large cone top	0.51	1.9
Horizontal, pressure	0.72	2.08
Sphere	0.62	1.87
Fiberglass	0.71	
Small storage	0.71	

200	250 psi
1.18	1.38
50	75
1.08	1.19
1.26	2.39
1.53	


  

200	250 psi
1.18	1.38
50	75
1.08	1.19
1.26	2.39
1.53	

200	250 psi
1.18	1.38
50	75
1.08	1.19
1.26	2.39
1.53	


Tanks, (Small)  
304 stainless steel




Size exponent	Factor
Dished head, 50 psi	0.68
Flanged, dished head	0.48
Cone top, bottom, legs	0.57
Flat top, bottom	0.93

# EQUIPMENT COST ESTIMATES 305

Thickeners, Clarifiers  
Rake mechanism, concrete tank, drive



Size exponent: 1.03  
Installation factor:  
1.63-2.61; avg. 2.12  
Module factor: 3.0  
Tank factor:  
Concrete/steel 0.7 for  
units under 40 ft diameter



## REFERENCES

- Allen, D. H., and R. C. Page. 1975. Revised techniques for predesign cost estimating. *Chemical Engineering* (March).
- Alonso, J. R. F. 1971. Estimating the costs of gas cleaning plants. *Chemical Engineering*.
- Axtell, Oliver, and James M. Robertson. 1986. *Economic Evaluation in the Chemical Process Industries*. John Wiley & Sons, New York.
- Beckman, James, ed. 1986. *Series Design of Equipment. Vol. 1, Plant Design and Cost Estimating*. American Institute of Chemical Engineers, New York.
- Bennett, Richard D. 1987. Evaporator, crystallizer costs. Swenson Process Equipment Inc., 15700 Lathrop Ave., Harvey, IL 60426; 1988, Matching Crystallizer to Material, *Chemical Engineering* (May 23): 118-127.
- Blecker, H. G., H. S. Epstein, and T. M. Nichols. 1974. Wastewater Equipment. *Chemical Engineering* (Oct.).
- Chase, D. J. 1970. Plant costs vs. capacity. *Chemical Engineering* (April).
- Chemical Engineering*, comp. & ed. 1979 and 1984. *Modern Cost Engineering: Methods and Data*. 2 vols. McGraw-Hill, New York.
- Chemical Engineering*, comp. & ed. 1979. *Process Technology and Flowsheets*. McGraw-Hill, New York.
- Clark F. D., and S. P. Terni. 1972. Thick wall pressure vessels. *Chemical Engineering* (April).
- Corripio, A. B., K. S. Chien, and L. B. Evans. 1982. Estimate cost of heat exchangers and storage tanks via correlations. *Chemical Engineering* (Feb.): 125-127.
- Desai, M. B. 1981. Preliminary cost estimating of process plants. *Chemical Engineering* (July 27).
- Epstein, L. D. 1971. Costs of standard vertical storage tanks and reactors. *Chemical Engineering* (July 13): 141-142.
- Fang, C. S. 1980. The cost of shredding municipal solid waste. *Chemical Engineering* (April 21): 151-152.
- Guthrie, Kenneth M. 1974. *Process Plant Estimating, Evaluation, and Control*. Craftsman Book Co., Solana Beach, CA.
- Hall, R. S., J. Matey, and K. J. McNaughton 1982. Current costs of process equipment. *Chemical Engineering* (April 5).
- Happel, J., and D. G. Jordan. 1975. *Chemical Process Economics*. Marcel-Dekker, New York; 219-231.
- Herkimer, Herbert. 1958. *Cost Manual for Piping and Mechanical Construction*. Chemical Publishing, New York.
- Hoerner, G. M. 1976. Nomograph updates process equipment costs. *Chemical Engineering* (May).
- Holland, F. A., F. A. Watson, and J. K. Wilkinson. 1974. How to estimate capital costs. *Chemical Engineering* (April).
- Huff, G. A. 1976. Selecting a vacuum producer. *Chemical Engineering* (March).
- Kharbanda, O. P. 1979. *Process Plant and Equipment Cost Estimation*. Craftsman Book Co., Solana Beach, CA.
- Klumper, L. V., and S. T. Stavsky. 1985. Updated cost factors: process equipment. *Chemical Engineering* (July 22): 73-77.
- . 1985. Commodity materials. *Chemical Engineering* (Aug. 19): 76-77.
- . 1985. Installation labor. *Chemical Engineering* (Sept. 16): 85-87.
- Koenig, A. R. 1980. Choosing economic insulation thickness. *Chemical Engineering* (Sept. 8).
- Kumana, Jimmy D. 1984. Cost update on specialty heat exchangers. *Chemical Engineering* (June 25): 169.
- Lindamood, D. M. 1985. Most economical thickness, hot-pipe insulation. *Chemical Engineering* (April 1): 96.
- Meyer, W. S. and D. L. Kime. 1976. Cost estimation for turbine agitators. *Chemical Engineering* (Sept.).
- Miller, J. S. and W. A. Kapella. 1977. Installed cost of a distillation column. *Chemical Engineering* (April).
- Moselle, Gary, ed. 1979. *National Construction Estimator*. Craftsman Book Co., Solana Beach, CA.
- Mulet, A., A. B. Corripio, and L. B. Evans. 1981. Estimating costs of distillation and absorption towers via correlations. *Chemical Engineering* (Dec. 28): 77-82.
- . 1984. Pressure vessels. *Chemical Engineering* (Oct. 5).
- Patrascu, Anghel. 1978. *Construction Cost Engineering*. Craftsman Book Co., Solana Beach, CA.

- Peters, M. S., and K. D. Timmerhaus. 1980. *Plant Design and Economics for Chemical Engineers*. McGraw-Hill, New York.
- Pikulik, A., and H. E. Diaz. 1977. Cost estimating for major process equipment. *Chemical Engineering* (Oct. 10):107-122.
- Purohit, G. P. 1985. Cost of double-pipe and multitube heat exchangers. *Chemical Engineering* (March 4):92-96. (April 1):85-86.
- Sommerville, R. F. 1970. Estimating mill costs at low production rates. *Chemical Engineering*. —. 1972. New method gives accurate estimate of distillation cost. *Chemical Engineering* (May).
- Swearingen, Judson S., and John E. Ferguson. 1983. Optimized power recovery from waste heat. *Chemical Engineering Progress* 79 (Aug):66-70.
- Ulrich, G. D. 1983. *A Guide to Chemical Engineering Process Design and Economics*. John Wiley & Sons, New York.
- Valle-Riestra, F. J. 1983. *Project Evaluation in the Chemical Process Industries*. McGraw-Hill, New York.
- Vatavuk, William M., and Robert B. Neveril. (1980-1983). Air pollution control systems (Parts 1-16). *Chemical Engineering* (Oct.-May).
- 1980. Pollutant capture hoods. *Chemical Engineering* (Dec. 1):111-115.
- 1984. Practical emissions control. *Chemical Engineering* (April 2):97-99.
- 1984. Gaseous emissions control. *Chemical Engineering* (April 30):95-98.
- Vogel, G. A., and E. J. Martin 1983. Estimating capital costs of facility components. *Chemical Engineering* 90 (24) (Nov. 28):87-90.
- 1984. Operating costs. *Chemical Engineering* (Jan. 9):97-100.
- 1984. Incinerator costs. *Chemical Engineering* (Feb. 6):121-122.

## APPENDIX 2

# COMPLETE PLANT COST ESTIMATING CHARTS

The following charts indicate the complete cost of plants to produce various chemicals in differing tonnages. The information has been assembled primarily from four sources: (1) curves on 54 plants published by Guthrie (1974), (2) curves on 18 plants published by *Chemical Engineering* (1973/1974), (3) 33 nomographs, and about 140 single plant size-cost data notations by Kharbanda (1979), and (4) several hundred recent plant construction notices in *Chemical Engineering's Construction Alert*. The first three sources are quite old, with most of the information gathered from the mid-60s through the early 70s. The last source was data from 1980 through 1987. Each source was inflation-corrected to 1987 (CE Index of 320) by means of the *Chemical Engineering* (CE) Index.

The first two references were probably quite authoritative when published, and represented contractor prices for that plant alone, plus the necessary raw material and product storage. The infrastructure for a "grass roots" plant, or even for minor utility and other required nonplant facilities was not included. The later two sources, on the other hand, are basically press-release information stating what the complete facility cost. This might include land, site development, and/or any of the infrastructure required to make the plant function. Costs would thus be higher, and the assembled data would be much more scattered because of each location's different requirements.

Both factors, the early data's age, and the most recent data's complete cost basis, tend to limit the accuracy of the plots. When considerable data were available, high, low and average lines were shown. Presumably the high values represent more infrastructure requirements. When only one data point (i.e., one plant cost at one size) was available, the capacity versus cost line was drawn with a slope of 0.64, the average size-cost exponent of Guthrie's 54 plants.

Normally it should be expected that the costs shown in these plots should be roughly correct, and perhaps on the high side. However, some of the data from the first three references appear to be very low, so caution should be used with all of the charts. They may be useful as a guide, but not too much confidence should be placed in their accuracy. The basis for the costs should be considered as a reasonably high value for the plant alone, plus storage, and the CE Index 320.